ADITYA ENVIRONMENTAL SERVICES PVT. LTD.
Testing Laboratory is certified by **ISO 9001:2015&ISO 45001:2018**
"Recognized under The Environment (Protection) Act, 1986" valid up to 24.04.2027
Laboratory: P-1, MIDC Mohopada, Rasayani, Dist. Raigad, 410222, E-mail: pglab@aespl.co.in
Tel: 9112844844, **CIN**: U74999MH2001PTC132101 **UDYAM**-MH-19-0029787
TC-7085

Test Report
(Microbiology – Water)

Ref. No.: AESPL/LAB/B/Mw-26/10/170 **Issue Date:** 19/10/2026

Name of Customer	:	Classic Promoters and Builders Pvt Ltd.			
Name of Site	:	F.P. No. 1074(pt) of TPS-IV of Mahim Division, in G/South Ward, Prabhadevi, Mumbai.			
Nature of Sample	:	Drinking water	**Location of Sample**	:	Labour Colony
Date of Sample Drawn	:	14/10/2026	**Time of Sample Drawn**	:	09:15 am
Sample Drawn By	:	ACD	**Transported By**	:	ACD
Date of Sample Receipt	:	15/10/2026	**Sample Identification**	:	Mw-26/10/170
Sample Quantity & Container	:	250 ml; Glass bottle.			
Date of Sample Analysis	:	15/10/2026 to 16/10/2026			

Environmental Conditions at site	:	Surrounding area is clear.
Transportation Condition	:	Water Temperature: < 6°C, Cold storage.
Project/ Job number	:	AESPL/Q/2023-24/CPBPL/72 dt 30.03.24
Reference of Sampling	:	AESPL/LAB/QR/7.3.3/R-03
Method of Sampling & Preservation	:	AESPL/LAB/SOP/7.3.1/M-01
Environmental Condition while Testing	:	Ambient Temperature: 20.8°C and Humidity: 61 %

Sr. No.	**Parameter, Unit**	**Result**	**Limits as per: IS 10500:2012**	**Method of Analysis**
1.	Coliform/100ml	Absent /100ml	Absent /100ml	IS:15185:2016
2.	E-coli/100ml	Absent /100ml	Absent/100ml	IS:15185:2016

Conformity Statement: Water sample is **Pass** as per IS 10500:2012 w. r. t. above mentioned tests.

Note:

1. The test report shall not be reproduced except in full, without written approval of laboratory.
2. Results relate only to the items tested.
3. Data provided by customer and results apply to the sample as received.

ADITYA ENVIRONMENTAL SERVICES PVT. LTD. RASAYANI

Himani P. Joshi
(Report Reviewed By)

N. K Shendye
(Authorized Signatory)

-End of Test Report-